



## Notice of Revised Pedernales Electric Cooperative Specifications

Revisions Posted September 12, 2019

### Residential and Commercial 100–200 Amp Meter Loop Specifications

Page 1 of 13, Note 7

- Extracted the following text from Note 7 and added as the third sentence to Note 6: “Steel poles must be capped to prevent water ingress and may be more than one piece if the final product is appropriately coupled and meets all other requirements.”
- Revised Note 7 to state: “Clearances from ground level to service attachment point shall be a minimum of 12'. This is to include all pole-mounted services and weatherheads mounted to the side of a structure and above the roof line of a structure. Refer to pages 5 and 6.”

Page 1 of 13, Note 9

- Moved to second page.

### Residential and Commercial 320 Amp Meter Loop Specifications

Page 1 of 14, Note 7

- Extracted the following text from Note 7 and added as the third sentence to Note 6: “Steel poles must be capped to prevent water ingress and may be more than one piece if the final product is appropriately coupled and meets all other requirements.”
- Revised Note 7 to state: “Clearances from ground level to service attachment point shall be a minimum of 12'. This is to include all pole-mounted services and weatherheads mounted to the side of a structure and above the roof line of a structure. Refer to page 13.”

Page 1 of 14, Note 9

- Moved to second page.