



**Notice of Revised Pedernales Electric Cooperative Specifications
Posted March 26, 2020**

Temporary Underground Electric Service

Revisions:

- Revised post depth from 12" to 24" on pages 2 and 3.