



Notice of Revised Pedernales Electric Cooperative Specifications Posted April 20, 2020

Note: Minor edits considered technically insignificant may not be listed.

Underground Installation Specifications

Revised specifications:

- 510-023 – Three-Phase Primary Conduit Arrangement Joint With Natural Gas (Horizontal Option)
 - Revised fourth bulleted note at top of page:
 - Was: “The maximum pressure of the gas line is less than 60 PSI.”
 - Now: “The maximum pressure of the gas line is 60 PSI or less.”

- 510-025 – Three-Phase Primary Conduit Arrangement Joint With Natural Gas (Stacked Option)
 - Revised fourth bulleted note at top of page:
 - Was: “The maximum pressure of the gas line is less than 60 PSI.”
 - Now: “The maximum pressure of the gas line is 60 PSI or less.”