



Notice of Revised Pedernales Electric Cooperative Specifications Posted July 10, 2020

Note: Minor edits considered technically insignificant may not be listed.

Residential and Commercial 320 Amp Meter Loop Specifications

- Revised text regarding wire size:
 - Page 3, "WIRE SIZE" section, first sentence:
 - Was "350 MCM aluminum or equivalent copper"
 - Now: "350 MCM copper or equivalent aluminum"
 - Pages 10, 11 & 12, drip loop note:
 - Was "350 MCM aluminum or copper equivalent"
 - Now: "350 MCM copper or equivalent aluminum"